## COMMONWEALTH OF KENTUCKY

## BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MURRAY NO. 1 WATER )
DISTRICT FOR A DEVIATION OF 807 KAR ) CASE NO. 94-247
5:066, SECTION 4(4), REGARDING WATER )
STORAGE )

## O R D E R

On June 24, 1994, the Murray No. 1 Water District ("Murray No. 1") applied for permission to deviate from Commission regulation 807 KAR 5:006, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. By Order of October 14, 1991 in Case No. 91-2831, Murray No. 1 was required to bring its water storage facilities into compliance with Commission regulations by July 1, 1994.

Murray No. 1 subsequently filed a letter from the City of Murray Public Works and Utilities ("City of Murray") stating that it would provide Murray No. 1's needed storage for the next three years from its 3.75 million gallons of storage capacity.

The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:

1. The total water storage capacity of Murray No. 1 is approximately 50,000 gallons.

Case No. 91-283, The Application of Murray No. 1 Water District for a Deviation Pursuant to 807 KAR 5:066 Section 5(4), Regarding Water Storage.

2. Murray No. 1's average daily water usage is approximately 107,000 gallons per day.

3. The City of Murray is willing to provide Murray No. 1 with the additional needed storage capacity for the next three years.

IT IS THEREFORE ORDERED that:

1. Murray No. 1 be and it hereby is granted permission to deviate from the provisions of 807 KAR 5:066, Section 4(4) until July 1, 1997.

2. Murray No. 1 shall take all necessary action to bring its water storage facilities into compliance with Commission regulations by July 1, 1997.

Done at Frankfort, Kentucky, this 20th day of July, 1994.

PUBLIC SERVICE COMMISSION

ATTEST: